



## ANEJO D

HIGH/LOW WATER ALARM TEST  
EC.02.03.05 EP 7

Date: \_\_\_\_\_

Frequency: Semiannual

EC.02.03.05: The hospital maintains fire safety equipment and fire building features.

EP 7: For automatic sprinklers system: Every 6 months, the hospital test water storage tank high and low water alarm. The completion date of the tests is documented.

NFPA 25-2011: 9.3; Table 9.1.1.2

## TEST INFORMATION:

## 1. HIGH LEVEL WATER STORAGE ALARM:

\_\_\_\_\_ COMPLIANCE

\_\_\_\_\_ NO COMPLIANCE

## 2. LOW LEVEL WATER STORAGE ALARM:

\_\_\_\_\_ COMPLIANCE

\_\_\_\_\_ NO COMPLIANCE

## OBSERVATION:

---

---

---

Test by: \_\_\_\_\_

Signature: \_\_\_\_\_

\*Entregar en la Oficina de Salud y Seguridad